



- NOTES:
1. MOTOR CONTROL COMPONENT DESIGN LIMITED TO A MAXIMUM OF 50 HP @ 480 VOLTS
  2. FOR LARGER HP APPLICATIONS, ALL COMPONENTS SHALL BE SIZED PROPERLY AND LOGISTICALLY ARRANGED BASED ON THIS DESIGN.

**DIMENSIONS IN INCHES**

SCALE:	N.T.S.	NO	REVISION	DATE	BY
DESIGN:	IAG /LS	1	CHANGED LENSE COLOR LPB-1	10-11-2013	JG
DRAWN BY:	JG	2	REVISED BOP-2 TO IOP	08-22-2014	JG
APPROVED BY:	WW	3	REVISED ENCLOSURE TYPE AS PER MEETING	03-03-2015	JG



WASTEWATER DIVISION,  
INDUSTRIAL AUTOMATION GROUP  
CITY OF  
ORLANDO, FLORIDA

TITLE:  
LIFT STATIONS STANDARDS  
> 50 HP VFD WITH SSRVS PUMP CONTROLLER  
FRONT ELEVATION AND GROUNDING DETAIL