



COMPONENT IDENTIFICATION
 REFLECTED ON BILL OF MATERIALS
 DRAWING # 504

NOTE 1:
 MOTOR CONTROL WIRING
 LIMITED TO A MAXIMUM OF:
 20 HP @ 230 VOLTS
 50 HP @ 460 VOLTS

| | | | | | | |
|------------------|--------------------------|------------|----|--|--|---------------|
| SCALE: N.T.S. | REVISIONS AS PER MEETING | 09-04-2013 | JG | WASTEWATER DIVISION, INDUSTRIAL AUTOMATION GROUP CITY OF ORLANDO, FLORIDA | LIFT STATIONS STANDARDS 25 HP TO < 50 HP DUPLEX SSRVS PUMP CONTROLLER FOR STATIONERY GENERATOR INTERIOR PANEL LAYOUT | SHEET 503B |
| DESIGN: IAG / LS | ADDED ITEM 42 | 06-26-2014 | JG | | | |
| DRAWN BY: JG | | | | | | |
| APPROVED BY: WW | REVISION | DATE | BY | | | |
| | NO | | | | | |