2100	FTB-100	1P 1	16GN 0001	RTU FTB-1-100:1 COMMON
2101	FTB-100	2P 2	16OR 1001	RTU FTB-101:1 PUMP # 1 RUNNING
2102	FTB-100	3P 3	16OR 2001	RTU FTB-104:4 PUMP # 2 RUNNING
2103	FTB-100	4P 4	16OR 2003	RTU FTB-101:2 PUMP # 3 RUNNING
2104	FTB-101	1P 1	16RD 1002	RTU FTB-300:1 PUMP # 1 START
2105	FTB-101	2P 2	16RD 1002	RTU FTB-300:2 PUMP # 1 START
2106	FTB-101	3P 3	16AQ 2002	RTU FTB-302:1 PUMP # 2 START
2107	FTB-101	4P 4	16AQ 2002	RTU FTB-302:2 PUMP # 2 START
2108	FTB-102	1P 1	16PL 3002	RTU FTB-300:3 PUMP # 3 START
2109	FTB-102	2P 2	16PL 3002	RTU FTB-300:4 PUMP # 3 START
2110	FTB-102	3P 3	16WT 1003	RTU FTB-101:3 PUMP # 1 HOA IN AUTO
2111	FTB-102	4P 4	16WT 2003	RTU FTB-105:1 PUMP # 2 HOA IN AUTO
2112	FTB-103	1P 1	16WT 3003	RTU FTB-101:4 PUMP # 3 HOA IN AUTO
2113	FTB-103	2P 2	16BK 0800	RTU FTB-105:2 PHM-1 FAILURE
2114	FTB-103	3P 3	16YL 0200	RTU FTB-102:2 STATION INTRUSION
2115	FTB-103	4P 4	16YL 1005	RTU FTB-103:1 PUMP # 1 SEAL FAILURE
2116	FTB-104	1P 1	16YL 2005	RTU FTB-106:2 PUMP # 2 SEAL FAILURE
2117	FTB-104	2P 2	16YL 3005	RTU FTB-103:2 PUMP # 3 SEAL FAILURE
2118	FTB-104	3P 3	16YL 1006	RTU FTB-103:3 PUMP # 1 HI TEMPERATURE ALARM FAILURE-MOTOR SHUTDOWN
2119	FTB-104	4P 4	16YL 2006	RTU FTB-106:3 PUMP # 2 HI TEMPERATURE ALARM FAILURE-MOTOR SHUTDOWN
2120	FTB-105	1P 1	16YL 3006	RTU FTB-103:4 PUMP # 3 HI TEMPERATURE ALARM FAILURE-MOTOR SHUTDOWN
2121	FTB-105	1P 1		SPARE FOR FUTURE USE
2122	FTB-105	3P 3	16YL 1017	RTU FTB-107:1 SPD-1 FAILURE
2123	FTB-105	4P 4	16YL 1027	RTU FTB-107:2 SPD-2 FAILURE
2124	FTB-106	1P 1	16YL 1037	RTU FTB-107:3 SPD-3 FAILURE
2125	FTB-106	2P 2		SPARE FOR FUTURE USE
2126	FTB-106	3P 3		SPARE FOR FUTURE USE
2127	FTB-106	4P 4		SPARE FOR FUTURE USE
2128	FTB-107	1P 1	16BN 0928	RTU FTB-302:3 BELL SILENCE
2129	FTB-107	2P 2	16BN 0929	RTU FTB-302:4 BELL SILENCE
2130	FTB-107	3P 3	16BN 0930	RTU / LIT-1 FTB-301:3 HIGH WET WELL LEVEL
2131	FTB-107	4P 4	16YL 0931	RTU / LIT-1 FTB-301:4 HIGH WET WELL LEVEL
2132	FTB-108	1P 1	16YL 0004	OPTI-FLOAT FTB-301:1 (1)
2133	FTB-108	2P 2	16YL 0933	OPTI-FLOAT FTB-303:4 (1)
2134	FTB-108	1P 3		SPARE FOR FUTURE USE
2135	FTB-108	2P 4		SPARE FOR FUTURE USE

P= PROTECTED TERMINAL SIDE

SCALE: N.T.S.	1	REVISED FIELD WIRING ID'S	10-25-2013	JG
DESIGN: IAG / LS	-	REVISED TITLE SHEET DESCRIPTION	06-26-2014	JG
DRAWN BY: JG				
APPROVED BY: WW	NO	REVISION	DATE	BY

WASTEWATER DIVISION,
INDUSTRIAL AUTOMATION GROUP

CITY OF
ORLANDO, FLORIDA

TITLE: LIFT STATIONS STANDARDS
25 HP TO < 50 HP
TRIPLEX SSRVS PUMP CONTROLLER FOR
FIELD WIRING ASSIGNMENTS OVERVIEW

SHEET
521